



CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - VAPOR RECOVERY PROGRAM



VAPOR RECOVERY CERTIFICATION

GASOLINE VAPOR RECOVERY SYSTEM MONITOR

Page 1 of 1

CERTIFICATION No.: GVRC 005:061:001

MANUFACTURER: Nupi Americas Inc., 1511 Superior Way, Houston, TX 77039
Contact Person: *Maurizio Matta Phone: (281) 590-4471 Fax: (281) 590-5268

DESIGN: Model Smartflex Underground Piping for Flammable Liquids – Nonmetallic Primary Carrier (PC) Pipe and Fittings for motor vehicle (MV) fuels, concentrated fuels (CT), high blend fuels (HB) and aviation and marine fuels (A&M), nominal diameters of 50, 63, 75, 90 and 100mm. Nonmetallic Secondary Containment (SC) Pipe and Fittings for motor vehicle (MV) fuels, concentrated fuels (CF), high blend fuels (HB) and aviation and marine fuels (A&M), nominal diameters of 63, 75, 110 and 125mm. Nonmetallic Integral Primary/Secondary Pipe System (PS) motor vehicle (MV) fuels, concentrated fuels (CT), high blend fuels (HB) and aviation and marine fuels (A&M), nominal diameters of 50/63, 63/75 and 90/125mm. Nonmetallic Normal Vent (NV) motor vehicle fuels (MV), concentrated fuels (CT), high blend fuels (HB) and aviation and marine fuels (A&M), nominal diameters 50, 63, 75, 90 and 110mm. Nonmetallic Vapor Recovery (VR) motor vehicle fuels (MV), concentrated fuels (CT), high blend fuels (HB) and aviation and marine fuels (A&M), nominal diameters 50, 63, 75, 90 and 110mm.

APPLICATION: For Stage I and II Systems.

INSTALLATION: To be installed in accordance with manufacturer's instructions and all applicable codes.

MARKING: Type of pipe and fittings: UGN = Underground Nonmetallic, PS = Integral Primary/Secondary, NV = Normal Vent, VR = Vapor Recovery; "For MV, HB, CT and A&M Fuels, (Control #) and U.L. Label.

CERTIFICATION: Certified for use with Stage I or II Vapor Recovery Systems where full or self service is provided.

* Revised 5-26-10 MA

This certification is made pursuant to the authority granted to the California State Fire Marshal as contained in Sections 41955 through 41960 inclusive, California Health and Safety Code. The certification is based upon independent tests or other technical data submitted by the applicant. CSFM staff has reviewed the test results and/or data but does not make an independent verification of any claims. This certification is not an endorsement or recommendation for the use of the item(s) specified. This certification should not be used to verify correct operational requirements or installation criteria.

Date Issued: **MAY 26, 2010**

Authorized By:

JAMES PARSESIAN

Supervising Deputy State Fire Marshal
Vapor Recovery Program